


CERTIFICATE

Certificate holder	STENFLEX Rudolf Stender GmbH Robert-Koch-Str. 17 22851 Norderstedt GERMANY
Product	Compensators made of elastomeric compound materials for warm water heating-plants
Type, Model	AS, AS-5, RS, VS
Testing basis	DIN 4809-1:1986-11
Mark of conformity	
Registration No.	3E002
Valid until	2023-11-30
Right of use	This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number. See annex for further information.

2022-02-24


Dipl.-Phys. Carlo Seiser
Head of Certification Body

ANNEX

Certificate	3E002 dated 2022-02-24
Technical Data	Manufacturer: ContiTech Ltd, Hungary Elastomer material: EPDM Reinforcement: Steelwire inlay Nominal width: DN 32, 40, 50, 65, 80, 100, 125, 150, 175, 200 Maximum operating temperature: 110 °C Maximum pressure: 10 bar
Testing laboratory/ Inspection body	TÜV SÜD Industrie Service GmbH Westendstr. 199 80686 München GERMANY
Test report(s)	1046010 dated 2007-12-04 1396138 dated 2010-01-20 1723016 dated 2011-10-31 2077704 dated 2013-12-18 2788300 dated 2017-11-02 3158777 dated 2019-11-14 3507783 dated 2022-02-04